

Biomass UK No.2 Ltd
St Helen's 1 Undershaft
London
EC3P 3DQ

Fire prevention measures at Barry

Our Reference
366068

9 October 2017

Victory House
Trafalgar Place
Brighton BN1 4FY
United Kingdom

Dear Sirs,

Mott MacDonald is an internationally renowned engineering consultancy that has been involved in power plant projects for over 100 years.

T +44 (0)1273 365000
F +44 (0)1273 365100
mottmac.com

In our experience, thermal power stations storing and handling combustible fuels require active fire protection measures which include firefighting water storage and associated fire pumps. We would consider the Barry renewable energy plant using advanced thermal conversion technology to be no different from any other thermal power station with regard to its requirement for these fire protection systems.



Dr Nick Escott
Project Principal
Nick.Escott@mottmac.com