



DRAWING NOTES:

1. THE DETAILS SHOWN ON THE DRAWING ARE FOR PLANNING AND ARE SUBJECT TO APPROVAL BY VALE OF GLAMORGAN COUNTY COUNCIL.
2. IN-SITU CONCRETE PAVEMENT TO BE 225mm THICK RC28/35 WITH A393 MESH BOTTOM AND A193 MESH TOP.
3. IN-SITU CONCRETE TO BE IN ACCORDANCE WITH THE CONCRETE SOCIETY TR86 AND BS EN 1992-1 AND BS EN 206-1.
4. REINFORCEMENT TO BE GRADE H 500N/mm² HIGH YIELD DEFORMED TYPE 2 BAR DETAILED IN ACCORDANCE WITH BS 4449 AND BS 8666.
5. CONCRETE PAVEMENT SLAB SURFACE LEVEL TOLERANCE TO BE +/- 15mm FROM DEIGN LEVELS STATED ON THE DRAWING. CONSTRUCTION LEVELS SHOULD ENSURE THAT NO PONDING OCCURS DUE TO FLAT SPOTS.
6. SURFACE REGULARITY TO HAVE NO MORE THAN 10mm DEVIATION UNDER A 2m STRAIGHT EDGE USING THE METHOD IN ANNEX C OF BS 8204-1. STEPS AT JOINTS TO BE NO GREATER THAN 5mm.
7. SLAB TO HAVE WIRE BRUSH FINISH WITH ARRIS EDGES. BRUSHED FINISH TO BE TRANSVERSE TO THE TYPICAL DIRECTION OF TRAVEL.
8. PAVEMENT SLAB NOMINAL 225mm THICK, 50mm COVER TO TOP, BOTTOM AND SIDES.
9. REINFORCEMENT TO LAP MINIMUM 400mm.
10. ALL EXISTING LEVELS TO BE CHECKED AND CONFIRMED ON SITE PRIOR TO CONSTRUCTION. ANY LEVELS DEVIATIONS ABOVE THE THE ALLOWABLE TOLERANCE ARE TO BE REPORTED BACK TO THE ENGINEER TO ENSURE PONDING DOES NOT OCCUR.
11. ADJOINING EXISTING PAVEMENT BUILD-UP AND DEPTH IS TO BE CONFIRMED ON SITE PRIOR TO CONSTRUCTION. JOINTING ARRANGEMENT AND DOWEL DEPTH PLACEMENT TO BE CONFIRMED PRIOR TO CONSTRUCTION.
12. BOND COATS CONFORMING TO BS 594987 SHALL BE APPLIED BETWEEN ALL BOUND LAYERS OF THE CARRIAGEWAY AT RATES OF SPREAD SPECIFIED IN BS594987 TABLE 2.
13. ALL BESPOKE DETAIL TO BE CONSULTED WITH THE ENGINEER.


10 cm - Caution as distortion can occur. ALL CIVIL DIMENSIONS ARE IN METRES - ALL STRUCTURAL DIMENSIONS ARE IN MILLIMETRES - ALL LEVELS ARE IN METRES.




EXISTING ASPHALT OVERLAY CONCRETE PAVEMENT, UTILITIES REINSTATEMENT DETAIL
SCALE 1:10




EXISTING RIGID PAVING, UTILITIES REINSTATEMENT DETAIL
SCALE 1:10




VERGE REINSTATEMENT DETAIL AIRFIELD
SCALE 1:10




EXISTING CONCRETE OVERLAY CONCRETE PAVEMENT, UTILITIES REINSTATEMENT DETAIL
SCALE 1:10




ASPHALT OVERLAY JOINT, UTILITIES REINSTATEMENT DETAIL
SCALE: NTS



VERGE REINSTATEMENT DETAIL WILDFLOWER MIX
SCALE 1:10



NEW ASPHALT PAVEMENT, UTILITIES REINSTATEMENT DETAIL
SCALE 1:10



VERGE REINSTATEMENT DETAIL
SCALE 1:10

52-P1-3	ISSUED FOR PLANNING	04/08/23	10	RLJ	RS
REV	DESCRIPTION	DATE	DRW	CHK	APP
Drawing Title:					
SERIES 1100 - KERBS AND FOOTWAYS					
STANDARD INDICATIVE					
OUTSIDE REINSTATEMENT DETAILS					
Burroughs Project No.:	Scale:	Original Paper Size:			
50192-00	1:10	A1			
Drawing Number:					
50192-BUR-HKF-XX-DR-C-1150					
Status:	Status Description:				
S2	FOR INFORMATION				
Revision:	Revision Description:				
P1.0	ISSUED FOR PLANNING				
This document is copyright of Burroughs Ltd. Use figured measurements only! DO NOT SCALE FROM DRAWING. Verify all dimensions prior to construction. Immediately report any discrepancies to Burroughs and if in doubt ASK. This drawing should be read in conjunction with all other associated project information					