


Symbol	Qty	Article number	Article name	Equipment
A	3	EXPFLA480WWD + TC4M	EXPLORER	1x 40 W
B	6	EXPFLA480WWD + WALL MOUNT	EXPLORER	1x 40 W
C	8	CBL90WWD	CITY BL	1x 9 W
D	8	TAUB08WWD	TAURUS	1x 6 W

NOTES  
 1. ALL EXTERNAL LIGHTS TO BE 100% DOWNWARD DIRECTIONAL LUMINAIRES  
 2. EXTERNAL LTG TO BE CONTACTOR CONTROLLED AS FOLLOWS: - WESTERN BOUNDARY TO BE SWITCHED OFF BETWEEN 6PM AND 6AM (APRIL TO SEPT) AND DIMMED TO 25% (OCT TO MARCH). HOWEVER ALL OTHER EXTERNAL LIGHTING TO BE CONTROLLED VIA PIR AND TIMER (SET TO 1 MIN MAX) AS SHOWN  
 3. SEE LEGEND FOR LUMINAIRE TYPES



NO.	DESCRIPTION	DATE	BY
1	ISSUED FOR PERMIT	01/10/2024	...
2	...	...	...
3	...	...	...

PROJECT: ...  
 DRAWING TITLE: ...  
 DRAWING NO: ...