

Rowlands, Ceiri

From: Fryer, Warren D. <wfryer@westernpower.co.uk>
Sent: 14 August 2019 09:20
To: Planning
Subject: Model Farm -FAO Ceri Rowlands

Hi MR Rowlands,

We have looked at the application for the proposed development at Model Farm, Port Road and have the following comments:-

- There is extensive 11kV network within the proposed development that will require diversion.
- There are LV supplies to buildings within the development and on the boundary of the development that will require attention.

We would expect the developer to contact us when they are in a position to progress the development to discuss the above.

Regards,

Warren Fryer

Planner

Western Power Distribution
Dyffryn Bach Terrace
Church Village Depot
Pontypridd
CF38 1BN

• 01443 219161
7 01443 494778
* wfryer@westernpower.co.uk

P Think of the environment. Do you need to print this email?

Western Power Distribution (South West) plc / Western Power Distribution (South Wales) plc / Western Power Distribution (East Midlands) plc / Western Power Distribution (West Midlands) plc
Registered in England and Wales
Registered number: 2366894 (South West) / 2366985 (South Wales) / 2366923 (East Midlands) / 3600574 (West Midlands)

Registered Office: Avonbank, Feeder Road, Bristol, BS2 0TB

This email and any files transmitted with it are confidential and intended solely for the use of the individual or entity to whom they are addressed.

If you have received this email in error please notify postmaster@westernpower.co.uk