

Rowlands, Ceiri

From: Fryer, Warren D. <wfryer@westernpower.co.uk>
Sent: 15 March 2021 15:38
To: Planning
Subject: Land At Model Farm

Follow Up Flag: Follow up
Flag Status: Completed

Hi Mr Rowlands,

We have looked at the application for the proposed development at Model Farm, Port Road and have the following comments:-

- There is extensive 11kV network within the proposed development that will require diversion.
- There are LV supplies to buildings within the development and on the boundary of the development that will require attention.

We would expect the developer to contact us when they are in a position to progress the development to discuss the above.

Please do not hesitate to contact me if you require any further information.

Regards,

Warren Fryer / Planner / Cardiff Construction

Western Power Distribution | Church Village Depot | Duffryn Bach Terrace | Church Village | Pontypridd | CF38 1BN

(- Direct Dial: +44 (0)1443 219161 – Internal: 219161

(- Mobile: 07544 158211

* - Email: wfryer@westernpower.co.uk

Team Support: Joshua Pamplin 01443 219010 jpamplin@westernpower.co.uk

Team Support: John Harley-Fox | 01443 219192 | jfox@westernpower.co.uk

Team Manager: David Roberts 01443 219045 dtroberts@westernpower.co.uk



P please consider the environment - do you really need to print this email?

Western Power Distribution (South West) plc / Western Power Distribution (South Wales) plc / Western Power Distribution (East Midlands) plc / Western Power Distribution (West Midlands) plc

Registered in England and Wales

Registered number: 2366894 (South West) / 2366985 (South Wales) / 2366923 (East Midlands) / 3600574 (West Midlands)

Registered Office: Avonbank, Feeder Road, Bristol, BS2 0TB

This email and any files transmitted with it are confidential and intended solely for the use of the individual or entity to whom they are addressed.

If you have received this email in error please notify postmaster@westernpower.co.uk